


This floor plan includes room "C." As presently understood, shelves are requested on only one side of room "C" over the sink. It is requested that similar shelves in the space available also be installed on the side of the room opposite the sink, and that fluorescent lighting fixtures similarly be installed with shade reflectors under the bottom shelf.

The sink model number (C-234-S) is obsolete. This unit is no longer offered under that number by the manufacturer, E. H. Sheldon Equipment Company. It is probable that either D-7573-S or D-5408-S is the correct model. Suggest consulting the manufacturer.

Please note that the total bench length proposed is 8'6". Probably it can be cut down at least a foot by the manufacturer.

It should be determined whether the "hood" includes fan and motor, also proper acid resistant ducts (such things as ammonia, hydrochloric acid and iodine fumes will be involved.).

Just
10 Aug 68
[Signature]



STAT

